



Deterministic Analysis Support for the Leningrad NPP Unit 2 ISA

Bruce Schmitt

Battelle, PNNL

April, 2002

LNPP ISA Development

- **The LNPP Unit 2 In-Depth Safety Assessment was a multinational cooperative effort**
 - Russia, United States, Sweden, Finland and Great Britain
- **Through the USDOE International Nuclear Safety Program, resources were allocated to support the LNPP Unit 2 ISA development**
 - Battelle, Pacific Northwest National Laboratory provided management and technical support
 - This presentation will review the deterministic support for the ISA

LNPP ISA Development

- **The current LNPP Unit 2 ISA grew from the P&DSA started in 1996**
 - level 1 PRA
 - limited DSA support
- **The P&DSA deterministic support at that time was based on a fully reconstructed Unit 2**
 - analysis support included 9 cases
 - DSA was to provide verification of selected success criteria

LNPP ISA Development

- **The original P&DSA analyses included:**
- cavity venting assessment
 - control rod success criteria (local and global)
 - control withdrawal (central and peripheral rods, hi and low power)
 - group distribution header blockage
 - group distribution header full break LOCA
 - loss of AC (preferred) power
 - main steamline LOCA
 - multiple MSRV stuck open
 - station blackout

LNPP ISA Development

- **In 1998-1999, the Unit 2 P&DSA was expanded to an ISA**
 - As-built configuration for June 2001 ISA submittal
- **LNPP responsible for development of final ISA documentation**
- **Within the ISA deterministic analysis support:**
 - USDOE provided financial support, Battelle provided management and technical support
 - LNPP provided data collection and subcontracting oversight
 - Kurchatov Institute (KI) was subcontracted to perform the deterministic assessments

ISA Deterministic Support

- **Deterministic analyses were needed to support both PSA conclusions and design basis events**
 - verification of ISA success criteria
 - verification of DB events
 - assessment of the impact of BDB events
 - support conclusions regarding EOI and plant performance within the AEA, OA and other related ISA studies

ISA Deterministic Support

- **Lessons learned from the P&DSA were implemented in selecting the initiating events (IE)**
 - KI was contracted to perform a review of the RF-GAN and LNPP Unit 2 TOB lists of IE
 - LNPP coordinated efforts between PSA group and KI for IE needed to support PRA conclusions
 - Multinational participants provided additional insights for needed IE
 - The KI review then provided a priority for selection of IE

ISA Deterministic Support

- **As part of the contracted work for the deterministic assessments, KI was also required to provide the following:**
 - Methodology descriptions for the selected IE
 - Justification for the selection of computer codes used
 - primary codes used were STEPAN and RELAP5
 - Current status of computer code validation efforts
 - Detailed calculation notebooks that documented the models and analyses
 - Review and concur with LNPP as-built design information
 - LNPP required to review and approve any generic RBMK data used (where Unit 2 specific data was not available)

ISA Deterministic Support

- **The deterministic support was split between four major contracts and included:**
 - **26 deterministic analysis reports**
 - 20 thermal hydraulic assessments
 - 5 neutronic assessments
 - 1 radiological assessment
 - **5 engineering assessment reports**
 - 4 thermal hydraulic assessments
 - 1 neutronic assessments
 - engineering assessments filled in gaps where computer code analyses were not needed to address an IE
 - **6 summary reports for the ISA report**
 - included a review of PSA success block diagrams

ISA Deterministic Support

- **For RBMKs, the design basis IE are grouped into 6 main categories**
 - Loss of Coolant Accidents
 - Reactivity Accidents
 - Core Cooling Accidents
 - Operational Accidents
 - Other Accidents
 - Beyond Design Basis Accidents

ISA Deterministic Support

- **Combining the RF-GAN list and Unit 2 TOB yield approximately 66 different IE for assessment**
 - approximately 25 IE were not specifically identified for assessment (within this contract area)
 - most of these were not thermal hydraulic or neutronic related (such as fire, flooding, earthquake, fuel cask drop, etc.) and were addressed elsewhere
- **The PSA needed an additional 8 IE to be reviewed**

ISA Deterministic Support

- **LOCA IE assessed include:**
 - Full break of group distribution header after non-return valve
 - Full break DGH upstream of CV (prior to ECCS actuation)
 - Full break of separator downcomer
 - Break of channel inlet pipe
 - Channel partial rupture
 - Rupture upstream of ICV
 - Break of channel outlet pipe
 - Break of main feedwater pipe: before power assembly non-return valve
 - Break of main feedwater pipe: after power assembly non-return valve
 - Main steam header valve does not fit (stuck open)
 - Small break beyond tightly sealed units of filling lines
 - Small break beyond tightly sealed units of pressure instrumentation lead

ISA Deterministic Support

Reactivity Accident IE assessed include:

- Continuous CPS rod withdrawal at rated and low power
- Continuous CPS rod withdrawal at zero power
- Continuous group rod withdrawal at rated and low power
- Continuous group rod withdrawal at zero power
- Additional absorber withdrawal
- Refueling error, including incorrect fuel loading
- Evacuation or entry of gas into CPS cooling channels
- Failure of one (any) CPS hardware component or logic resulting in spontaneous withdrawal or shutdown of a CPS rod group
- Spontaneous movement of one CPS rod beyond core

ISA Deterministic Support

- **Operational Transients assessed include:**
 - Generator load rise (generators 1 and 2)
 - Turbine trip (turbines 1 and 2)
 - Excessive feedwater flow
 - Reduction in feedwater temperature (loss of feedwater preheaters)
 - Excessive steam flow because of steam pressure regulator failure
 - Excessive steam flow because of unintentional turbine bypass valve opening
 - False ECCS actuation (high power and low power)
 - Trip of one (50%) or two (100%) operating turbine generators
 - Trip of one of two operating turbine generators

ISA Deterministic Support

- **Other Transients**
 - (not addressed within this work ... fire, explosion, cask drop, etc.)
- **Beyond Design Basis Accidents assessed include:**
 - Full pipe or MCP header break
 - Main steam line break
 - Total loss of plant power (Station Blackout)
 - Loss of AC Power
 - Loss of Feedwater
 - Partial flow rate loss
 - Main heat sink loss
 - Maximum reactivity insertion with continuous CPS rod withdrawal at minimum controllable power level 5% of rated
 - Maximum reactivity insertion with continuous CPS rod withdrawal at rate power

ISA Deterministic Support

- **PSA and other deterministic analyses include:**
 - Determination of reactivity local and global success criteria
 - Determination of short-term ECCS success criteria
 - Determination of long-term ECCS success criteria
 - Use of CPS for long-term cooling
 - Recovery of over-heated core
 - Use of Spir for long-term cooling
 - ECCS header rupture
 - Depressurization of the deaerators under long-term cooling

Significant Conclusions from Analyses

- **Short-term ECCS (accumulators) not required**
 - Note: not included in ISA submittal as this still under assessment
- **Reduced number of control rods required for shutdown**
 - Note: not included in ISA submittal as this still under assessment
 - Does not yet include long-term shutdown requirements (xenon burnout)
- **DBA IE were effectively validated**
 - Exception: ISA did identify potential single failure in LT ECCS
 - Corrective actions identified

Significant Conclusions from Analyses

➤ Feedwater Pipe Rupture

- BDBA for Unit 2
- Operators have >1 hr to align AFWP for recovery

➤ ECCS Header Rupture

- Operator recovery actions identified, with 20-30 minute timeframe

➤ Downcomer Rupture

- Operator actions identified for early shutdown of MFWP
- Operator actions identified for recovery from DGH CV non-closure, with 40-50 minute timeframe

Significant Conclusions from Analyses

- **Recovery from an over-heated core**
 - Potential operator recovery actions identified and timeframe available
- **Accident management for long term-term loss of makeup**
 - Potential operator recovery actions identified and timeframe available
 - Use of CPS and SPiR for long-term cooling to limit consequences of BDBA
- **Long-term Deaerator pressure control**
 - Possibility for loss of LFWP and FWP (long-term deaerator pressure loss)
 - Potential operator recovery actions and design changes identified

Significant Conclusions from Analyses

- **Provided verification of required plant equipment performance**
- **Operator actions defined throughout the assessments**
 - Provided verification of many PSA operator actions
- **Operator actions were identified that were not within current procedures**
 - Primarily in the area of accident management for BDB events
 - Most significant fractional contribution to improve plant risk is through EOI